

## WEST BENGAL POLLUTION CONTROL BOARD

( Department of Environment, Govt. of West Bengal ) Paribesh Bhawan

Bldg. No. 10A, LA Block, Sector-III, Salt Lake City Kolkata-700 098

Tel: 2335-9088, 2335-7428, 2335-8211, 2335-8073, 2335-6731 2335-0261, 2335-8212, 2335-8213, 2335-8861, 2335-5975

Fax: (0091) (033) 2335-6730 / 2335-2813

**DATED: 29-01-2007** 

MEMO NO.: 2929 -7/WPBD-CONT(1375)/02

## **CLOSURE ORDER**

WHEREAS, **M/S. SHYAM FERRO ALLOYS LTED**. located at Angadpur, Durgapur, Dist. – Burdwan, PIN – 713 215. (hereinafter referred as the industry) was inspected by the Regional Officials the West Bengal Pollution Control Board (hereinafter referred as the Board) along with the District Officials on a routine monitoring visit on 09-11-2006 at 23-15 hours.

WHEREAS, during inspection it was noted that all four ferro alloy plants of the industry were in operation without the pollution control system in operational condition. The air pollution Control system remained idle during operation resulting in high emission from the stack. There was also high secondary emission from the unit.

WHEREAS, a hearing was conducted involving the industry at the Head Office of the Board on 22-12-2006

WHEREAS, during hearing The Directior of the industry submitted that there was a failure of the auxiliary fans and they could not operate the air pollution control system.

NOW THEREFORE, in exercise of the powers conferred under Air (Prevention & Control of Pollution) Act, 1981 and Environment (Protection) Act, 1986 and Rules made thereunder and in consideration of the inspection report dated 09-11-2006 M/S. SHYAM FERRO ALLOYS LTD., is hereby directed as follows

1. That, all the four ferro alloy plants of the industry will remain closed till further direction from the Board.

In case of the non-compliance of the above directions by the industry the Board may have to issue necessary regulatory order on the entire plant operations at the above address without any further reference.

This has the approval of the Competent Authority.

Order

Sd/-

(Dr. D. Chakraborty)

Chief Scientist & Head-Technical Cell West Bengal Pollution Control Board